

**LEAD AND COPPER TEST RESULTS  
MILLBURN ELEMENTARY SCHOOL**

**Samples Taken: September 9, 2016**  
**Results Posted: December 8, 2016**

NONE of the samples taken at Millburn Elementary School exceeded the acceptable levels for copper and lead.

All of the lead results were within acceptable limits. All of the tests showed lead levels of less than 0.0020 mg/L. Levels at or less than 0.015 mg/L are considered acceptable.

All of the copper tests were within acceptable limits. Four of the copper tests showed copper levels at <0.150 mg/L with one test showing a level of 0.260 mg/L. Levels at or below 1.3 mg/L are acceptable for copper.

If you have any questions regarding these results, please contact Stephen Johns @ 847-356-8331. The water test results for copper and lead at Millburn Elementary School are listed below.

Stephen Johns, Ed.D.  
Business Manager/CSBO  
Email: sjohns@millburn24.net  
Phone: 847-245-2920

**LEAD/COPPER SAMPLING SITES AND RESULTS**

ID # IL3019562

FACILITY NAME: Millburn School District #24

MONITORING PERIOD: 11/14-12/30/16

Tier 1 Site	Tier 2 Site	BLDG Name	TAP LOCATION	(LAB USE) Sample ID	DATE SAMPLED	(LAB USE) RESULT COPPER (mg/L)	(LAB USE) RESULT LEAD (mg/L)
			Old Kitchen Area	1611246-01	9/9/2016 6:20:00AM	<0.150	<0.0020
			DF Band Ramp	1611246-02	9/9/2016 6:25:00AM	<0.150	<0.0020
			DF 5th Grade	1611246-03	9/9/2016 6:35:00AM	<0.150	<0.0020
			DF 1st Grade	1611246-04	9/9/2016 6:45:00AM	<0.150	<0.0020
			DF 4th Grade	1611246-05	9/9/2016 6:55:00AM	0.260	<0.0020

90th Percentile: Cu 0.205 mg/l Pb <0.0020 mg/l

Acceptable Level: Cu 1.3 mg/l Pb 0.015 mg/l